

MARINE CORPS BASE, CAMP LEJEUNE

Name of Water System: Marine Corps Air Station
 Water System ID#: 04-67-042
 Type of System: Community
 Source of Water: Ground
 Parameter: Trihalomethane
 Contaminant ID: 2950
 Method Code: 215
 Type of Sample: D-Regular

Type of Treatment: Chlorinated
 Fluoridated
 Filtered
 Lime
 Water Softener

Samples Collected by: Water Quality Control Lab-ID#37807
 Samples Analyzed by: Grainger Laboratories Inc
 ID#-37709

JTC Environmental Consultants,
 Rockville, Maryland 20850

CLW
00000001243

Collected	Analyzed	Sampling Site # 1		Sampling Site # 2		Sampling Site # 3		Sampling Site # 4		Sampling Site # 5		Quarterly Average PPB	ANNUAL Average PPB
		Bldg AS-110 WTP Plant TAP	Time	Bldg G-520 Consumer Tap	Time	Bldg AS-4025 Consumer Tap	Time	Bldg 710 Consumer Tap	Time	Bldg 2800 Consumer Tap	Time		
12-29-83	01-12-84 See Note #1	1255	0.055	1354	0.077	1304	0.112	1323	0.125	1313	0.131	100	101
03-27-84	04-05-84 See Note #1	0952	0.081	1053	0.138	1018	0.145	1037	0.128	1029	0.141	127	107.5
06-27-84	07-10-84 See Note #1	1240	0.081	1231	0.159	1250	0.137	1311	0.140	1301	0.158	135	117.5
09-21-84	10-02-84 See Note #1	1023	0.082	0952	0.154	1030	0.126	1059	0.154	1044	0.186	140	125.5
13-29-85	04-29-85 See Note #2	1018	Broken in Transit	1105	0.267	1058	0.142	1000	0.172	1010	0.215	199	158
15-1-85	05-28-85 See Note #2	See Note #3	0.056	See Note #3	0.118	See Note #3	0.105	See Note #3	0.104	See Note #3	0.173	111	150

NOTES:

- Analysis performed by Grainger Laboratories Inc.
- Analysis performed by JTC Environmental Consultants, Inc.
- Samples collected between 0800-1300 on 15 May 1985

Caused higher Average

STANDARD
100 PPB

Encl (1)